

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

## TR-Electronic GmbH

Eglisshalde 6, 78647 Trossingen, Germany

the Certificate No: **Z11499** for the PROFINET IO Device:

Model Name: C\_EPN2  
Revision: SW/FW: V2.5.0; HW: 2  
Identnumber: 0x0153; 0x0103  
GSD: GSDML-V2.35-TR-0153-PNRotative2-20210225.xml  
DAP: ID\_DAP\_1: C\_EPN2; 0x00000001

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.35
<input checked="" type="checkbox"/> Conformance Class	C
<input checked="" type="checkbox"/> Optional Features	Legacy, FSU, MRP
<input checked="" type="checkbox"/> Application Class	Isochronous
<input type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	Version 2.4.1 with annex spirta
<input checked="" type="checkbox"/> Tester	SIEMENS AG, Fürth, Germany, PN422-3

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **May 12, 2027** the certificate is valid for life.

Karlsruhe, May 22, 2024



(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.



(Xaver Schmidt)



(Frank Moritz)